CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-1518:102 Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Prefco Products, Inc., 2823 Route 413, Buckingham, PA 18912

Contact: Richard McNutt (215) 340-1707

DESIGN: Models 5600 fire rated dampers. Models listed below:

Models	Mounting	Rating	Single Size	In. Mult	Multiple Size, In.	
	Position	Hour	W	Н	W	Н
5650F	V	1-1/2	35-3/4	6-7/8	NA	NA
			23-3/4	17-3/4	NA	NA
	Н		16	17-3/4	NA	NA
	V	3	24	18	NA	NA
5660F	V	1-1/2	30	30	NA	NA
	Н		22	20	NA	NA
	V	3	30	30	NA	NA
5600F	V	1-1/2	29-7/8"	Diameter Round		
	Н		12″	Diameter Rou	meter Round	
	V	3	30"	Diameter Round		
5630F	V	1-1/2	14-7/8"	Diameter Rou	ınd	

Refer to listee's data sheet for detailed product description and operational

considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL: Listed as fire rated dampers for use in heating, ventilating and air conditioning duct systems

passing through fire resistive walls and partitions.

NOTE: Leakage rating not evaluated. Refer to CSFM Listing Category 3230 for leakage rated

dampers.

10-20-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 17, 2002 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Supervising Deputy

Program Manager